

Paul Pimentel

From: webmaster@cpuc.ca.gov
Sent: Monday, October 28, 2019 10:51 AM
To: usrb@cpuc.ca.gov
Cc: Paul Pimentel
Subject: (External):Electric Safety Incident Reported- Southern California Edison Company
Incident No: 191028-9399

The Following information regarding this incident has been reported:

Reporting Date: 10/28/2019 10:44:01 AM
Incident Date: 10/28/2019 @ 8:55 a.m.
Reported By: Paul C. Pimentel, Senior Manager
Utility Name: Southern California Edison Company
Phone Number: (626)302-5830
Email Address: paul.pimentel@sce.com

Incident Location: Near Las Virgenes Road/Highway 101 Calabasas, Los Angeles County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Milo
- Voltage (KV): 16 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: () -

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report out of an abundance of caution as it may involve an event that meets the subject of significant public attention or media coverage reporting requirement. Preliminary information indicates a relay occurred on the Milo 16 kV circuit out of Valdez Substation at 8:51 a.m. A brush fire known as the Oak Fire was reported shortly thereafter. The forward progress has been stopped and the fire consumed approximately 10 acres. There is no indication of any structures damaged. The investigation is ongoing.