

**From:** Robert Ramos <[Robert.Ramos@sce.com](mailto:Robert.Ramos@sce.com)>  
**Date:** October 31, 2019 at 10:10:40 PM PDT  
**To:** "[Majed.Ibrahim@cpuc.ca.gov](mailto:Majed.Ibrahim@cpuc.ca.gov)" <[Majed.Ibrahim@cpuc.ca.gov](mailto:Majed.Ibrahim@cpuc.ca.gov)>  
**Cc:** Paul Pimentel <[Paul.Pimentel@sce.com](mailto:Paul.Pimentel@sce.com)>  
**Subject:** CORRECTION - Fwd: (External):Electric Safety Incident Reported- Southern California Edison Incident No: 191031-9409

CORRECTION:

Majed,  
The Rainbow 16kV is out of Somis Substation.

Rob Ramos  
Director of Risk & Claims Mgmt  
626-302-3136

Begin forwarded message:

**From:** <[webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov)>  
**Date:** October 31, 2019 at 8:15:19 PM PDT  
**To:** <[usrb@cpuc.ca.gov](mailto:usrb@cpuc.ca.gov)>  
**Cc:** <[Robert.Ramos@sce.com](mailto:Robert.Ramos@sce.com)>  
**Subject:** (External):Electric Safety Incident Reported- Southern California Edison Incident No: 191031-9409

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/31/2019 8:02:56 PM  
**Incident Date:** 10/31/2019 @ 6:15 p.m.  
**Reported By:** Robert Ramos, Director of Risk  
**Utility Name:** Southern California Edison  
**Phone Number:** (626)302-3136  
**Email Address:** [Robert.Ramos@sce.com](mailto:Robert.Ramos@sce.com)

**Incident Location:** South Mountain Santa Paula, Ventura

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? No (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? Yes

**Cause of Incident:** Fire (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Rainbow
- Voltage (KV): 16kV
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** Out of an abundance of caution, SCE submits this report as it may involve an event that meets the subject of significant public attention or media coverage reporting requirement. Preliminary information reflects a brush fire known as the Maria Fire was reported on October 31, 2019, at approximately 6:13 p.m. Our information also reflects that the Rainbow 16kV Circuit out of Wakefield Substation was re-energized in this area at approximately 6:00 p.m. SCE is reporting the incident due to the close in time proximity between these two events. Our investigation is ongoing.