

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>

Sent: Thursday, May 7, 2020 7:30 AM

To: usrb@cpuc.ca.gov <usrb@cpuc.ca.gov>

Cc: Paul Pimentel <Paul.Pimentel@sce.com>

Subject: (External):Electric Safety Incident Reported- Southern California Edison Company Incident No: 200507-13489

CAUTION EXTERNAL EMAIL

The Following information regarding this incident has been reported:

Reporting Date: 5/7/2020 7:18:35 AM

Incident Date: 5/7/2020 @ 2:15 a.m.

Reported By: Paul C. Pimentel, Senior Manager

Utility Name: Southern California Edison Company

Phone Number: (626)695-4705

Email Address: paul.pimentel@sce.com

Incident Location: Near 146 Hollister Ranch Road (main gate) Hollister Ranch, Santa Barbara County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Concepcion
- Voltage (KV): 16 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report out of an abundance of caution as it involves an event that may meet the subject of significant public attention or media coverage reporting requirement. Preliminary information reflects SCE facilities experienced relay activity at 1:52 a.m. According to the Santa Barbara County Fire Department, the Hollister Fire was reported at approximately 2:17 a.m. and has burned about 200 acres. SCE is monitoring the event and the investigation continues.