

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>

Sent: Thursday, December 3, 2020 10:21 AM

To: usrb@cpuc.ca.gov <usrb@cpuc.ca.gov>

Cc: Eric Coolidge <Eric.Coolidge@sce.com>

Subject: (External):Electric Safety Incident Reported- Southern California Edison Company Incident No: 201203-13712

***** EXTERNAL EMAIL - Use caution when opening links or attachments *****

The Following information regarding this incident has been reported:

Reporting Date: 12/3/2020 10:00:51 AM

Incident Date: 12/3/2020 @ 2:05 a.m.

Reported By: Eric Coolidge, Senior Manager

Utility Name: Southern California Edison Company

Phone Number: (626)664-6118

Email Address: eric.coolidge@sce.com

Incident Location: 23920 California Avenue Hemet, Riverside

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? No

Cause of Incident: Other (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Rotec
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report out of an abundance of caution as it involves an event that may meet the subject of significant public attention or media coverage reporting requirement. According to the Riverside County Fire Department, the Cerritos Fire in Hemet was reported at approximately 2:06 a.m. and has burned about 200 acres. Preliminary information indicates that in the area of the reported fire there was a tree that fell over during a period of high winds, which fell onto SCE low voltage conductors. SCE is monitoring the event and the investigation continues.