

CORRECTION TO ELECTRIC SAFETY INCIDENT REPORT:

From: Eric Coolidge
Sent: Friday, July 31, 2020 2:33 PM
To: [redacted]@cpuc.ca.gov
Cc: [redacted]
Subject: Fw: (External):Electric Safety Incident Reported- Southern California Edison Company
Incident No: 200731-13583

[Name of Addressee Redacted],

In error, I listed the fire as approximately 300 acres at the time of the report. The fire was approximately 3 acres at the time of the report.

Best regards,
Eric Coolidge

ELECTRIC SAFETY INCIDENT REPORT:

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>
Sent: Friday, July 31, 2020 1:56 PM
To: usrb@cpuc.ca.gov <usrb@cpuc.ca.gov>
Cc: Eric Coolidge <Eric.Coolidge@sce.com>
Subject: (External):Electric Safety Incident Reported- Southern California Edison Company Incident No: 200731-13583

CAUTION EXTERNAL EMAIL

The Following information regarding this incident has been reported:

Reporting Date: 7/31/2020 1:55:15 PM

Incident Date: 7/31/2020 @ 11:55 a.m.

Reported By: Eric Coolidge, Senior Manager

Utility Name: Southern California Edison Company

Phone Number: (626)664-6118

Email Address: eric.coolidge@sce.com

Incident Location: 34 Shirley Drive Canoga Park, Los Angeles

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Energy
- Voltage (KV): 16
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____ - _____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report out of an abundance of caution as it involves an event that may meet the subject of significant public attention or media coverage reporting requirement. According to the Ventura County Fire Department, the Shirley Fire was reported at approximately 11:54 a.m. and has burned about 300 acres. Preliminary information reflects downed low voltage conductors in the area of the reported fire. We have no indication of any primary circuit activity. SCE is monitoring the event and the investigation continues.