

**From:** [webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov) <[webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov)>

**Sent:** Monday, December 7, 2020 3:51 PM

**To:** [usrb@cpuc.ca.gov](mailto:usrb@cpuc.ca.gov) <[usrb@cpuc.ca.gov](mailto:usrb@cpuc.ca.gov)>

**Cc:** Eric Coolidge <[Eric.Coolidge@sce.com](mailto:Eric.Coolidge@sce.com)>

**Subject:** (External):Electric Safety Incident Reported- Southern California Edison Company Incident No: 201207-13722

**\*\*\* EXTERNAL EMAIL - Use caution when opening links or attachments \*\*\***

**The Following information regarding this incident has been reported:**

**Reporting Date:** 12/7/2020 3:49:29 PM

**Incident Date:** 12/7/2020 @ 11:20 a.m.

**Reported By:** Eric Coolidge, Senior Manager

**Utility Name:** Southern California Edison Company

**Phone Number:** (626)664-6118

**Email Address:** [eric.coolidge@sce.com](mailto:eric.coolidge@sce.com)

**Incident Location:** 16799 South Mountain Road Santa Paula, Ventura

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? No (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? Yes
- Media Coverage? No

**Cause of Incident:** Other (Other Cause: )

**Agencies on Scene:**

**Facilities Affected:**

- Utilities Facilities: Petit
- Voltage (KV): 16
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** SCE submits this report out of an abundance of caution as it involves an event that may meet the subject of significant public attention or media coverage reporting requirement. According to the Ventura County Fire Department, the Cornell Fire in Santa Paula was reported at approximately 11:44 a.m. a.m. and has burned approximately 175 acres. Preliminary information indicates that in the area of the reported fire there was a tree that fell over during a period of high winds, which fell onto SCE low voltage conductors, causing damage to SCE and customer owned facilities. SCE is monitoring the event and the investigation continues.