

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>

Sent: Sunday, February 28, 2021 11:49:21 AM

To: usrb@cpuc.ca.gov <usrb@cpuc.ca.gov>

Cc: Paul Pimentel <Paul.Pimentel@sce.com>

Subject: (External):Electric Safety Incident Reported- Southern California Edison Company Incident No: 210228-14790

***** EXTERNAL EMAIL - Use caution when opening links or attachments *****

The Following information regarding this incident has been reported:

Reporting Date: 2/28/2021 11:34:43 AM

Incident Date: 2/28/2021 @ 4:20 a.m.

Reported By: Paul C. Pimentel, Senior Manager

Utility Name: Southern California Edison Company

Phone Number: (626)695-4705

Email Address: Paul.pimentel@sce.com

Incident Location: Malibu Canyon Road/Malibu Knolls Road Malibu, Los Angeles County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? Yes

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Serra
- Voltage (KV): 16 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report as it may involve an event that meets the subject of significant public attention or media coverage reporting requirement. Preliminary information indicates the Knolls Fire was reported at 4:24 a.m. Forward progress was stopped and the fire burned approximately 5 acres. There were no structures damaged nor injuries reported. Our information indicates a RAR on the Serra 16kV Circuit out of Crater Substation experienced a relay at 4:16 a.m. The investigation is ongoing.