

August 3, 2020

202006570

PUBLIC UTILITIES COMMISSION
STATE OF CALIFORNIA
ATTN: SAFETY AND ENFORCEMENT DIVISION
320 W FOURTH STREET SUITE 500
LOS ANGELES CA 90013

Re: Date of Incident: July 6, 2020
Location of Incident: Near 25000 Block of Pacy Street/Placerita Canyon Road,
Santa Clarita

Ladies and Gentlemen:

In accordance with the reporting requirements set forth in Resolution E-4184, this letter supplements the notice Southern California Edison Company (SCE) provided to the Commission via the web-based reporting system on Monday, July 6, 2020 at 12:10 p.m. regarding the above-referenced incident. SCE is required to submit this information pursuant to Commission instructions, resolutions and the Public Utilities Code, and submits this report under Public Utilities Code Section 315.

On Monday, July 6, 2020, at 10:11 a.m., the Los Angeles County Fire Department (LACFD), notified SCE of a brush fire identified as the Cambria Fire in Santa Clarita. SCE personnel responded and de-energized the transformer on Pole No. 1261559E resulting in an interruption of electric service to 2 customers. Although it was initially reported the Cambria Fire burned approximately 5 acres before it was extinguished by the LACFD, the burn area has been revised downward to 2.5 acres of vegetation. Furthermore, approximately 20 feet of a wood property-line fence sustained damage in the fire.

Once our personnel were permitted access to the subject area, our first responder observed what appeared to be evidence of arcing due to contact between an aluminum preform wire and an energized 350 secondary conductor at Pole No. 1261559E. Repairs to the involved SCE facilities consisted of replacing the preform and reconfiguring the service connections. Electric service to the affected customers was restored at approximately 2:30 p.m. that same day.

SCE is unaware of any additional property damage or injuries as a result of this incident.

Sincerely,

Jose Moran

Jose Moran