

May 27, 2021

202104879

PUBLIC UTILITIES COMMISSION
STATE OF CALIFORNIA
ATTN: JOCELINE PEREIRA
320 W FOURTH STREET SUITE 500
LOS ANGELES CA 90013

Re: Date of Incident: May 2, 2021
Location of Incident: Near 210th Street West/West Avenue D, Lancaster, California

Dear Joceline Pereira:

In accordance with the reporting requirements set forth in Resolution E-4184, this letter supplements the notice Southern California Edison Company (SCE) provided to the Commission via the web-based emergency reporting system on Sunday, May 2, 2021 at 11:50 p.m. regarding the above-referenced incident. SCE is required to submit this information pursuant to Commission instructions, resolutions and the Public Utilities Code, and submits this report under Public Utilities Code Section 315.

At approximately 8:10 p.m. on May 2, 2021, SCE received notification from the Los Angeles County Sheriff's Department (LACSD) of a fire burning near 210th Street West and West Avenue D, Lancaster. When SCE personnel responded and patrolled the area, they encountered a LACSD Deputy who advised that he observed what he described as arcing power lines and sparks falling from Pole No. 1950443E, which blew into vegetation in a southeasterly direction and ignited a brush fire called the Delta Fire. The Delta Fire was reported at 7:58 p.m. in an unincorporated area of Lancaster, California. The area at the time of the fire was experiencing gusty northwest winds.

SCE personnel inspected the facilities identified by the Deputy, and observed pitting on the top and middle phases (336 ACSR conductors) between Pole Nos. 1950443E & 4607926E on the Bailey-Neenach-Westpac 66 kV circuit. SCE records reflect a circuit relay at 7:55 p.m. SCE field personnel also discovered fire damage to guy stub Pole No. 1560334E which supported guying on the Bledsoe and Duntley 12 kV circuits out of Neenach Substation.

The Los Angeles County Fire Department (LACFD) was the lead agency managing the fire suppression activities and the investigation in the cause of the fire. Forward progress of the Delta Fire was stopped as of May 3, 2021 and it burned approximately 400 acres of vegetation with no reported structures damaged or destroyed. SCE re-sagged all 3 conductors between Pole

Public Utilities Commission

May 27, 2021

Page 2 of 2

Nos. 1950443E & 4607926E and replaced the guy stub pole. SCE is not aware of any injuries caused by the fire.

Sincerely,

A handwritten signature in blue ink, appearing to read "Bernice", is written over a light blue grid background.

Bernice Cordero